

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Rajeev Kumar, Chemist & Lab staff

(Name of Officers with designation) from District Water Testing Lab PHED Bhiwani

inspected the Vaish International School, Near Goushala Bhiwani

(Name & Address of the school) on 14/10/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1260 & 1297 dated 15/10/2024

of District Water Testing Lab, Bhiwani (PHED Lab) certified that the

Vaish International School, Bhiwani (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 Months


CHEMIST
Public Health Engg. Lab

Signature with Seal: Bhiwani

Name: Rajeev Kumar

Designation: Chemist

Name & Address of the Office / Department: DWTL, PHED, Mehram Road, Bhiwani

To Vaish International School,
Near Goushala, Bhiwani
(Name & Address of the Institution)



Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY ,BHIWANI

Website :- <https://phedharyana.gov.in/>

Memo No:- 1260

Date:- 15/10/2024

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : BHW/02374/10/2024 / Private		Sample Details	Date & Time
Sender :	VAISH MAHAVIDYALYA TRUST	Collected By	sahil
Location :	, VAISH INTERNATIONAL SCHOOL , NEAR GAUSHALA BHIWA	Collection Date	10/10/2024 at 09:48
Sample Description :	Drinking Water	Received at lab	14/10/2024 at 10:40
Latitude / Longitude :	76.130997 / 28.785926	Analysis Start Date	14/10/2024
		Analysis End Date	14/10/2024
		Sample Quantity	2 ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	151	500 mg/lt.	2000 mg/lt.	APHA 24th Edition -2540 C
2	Total Hardness as CaCo3	130	200 mg/lt.	600 mg/lt.	APHA 24th Edition -2340 C
3	Calcium as Ca	8.03	75 mg/lt.	200 mg/lt.	APHA 24th Edition-3500-Ca B
4	Magnesium as Mg	20.65	30 mg/lt.	100 mg/lt.	APHA 24th Edition -3500 Mg B
5	Iron as Fe	0.01	1.0 mg/lt.	1.0 mg/lt.	USEPA
6	Chloride as Cl	38.99	250 mg/lt.	1000 mg/lt.	APHA 24th Edition -4500 Cl-B
7	Sulphate as So4	14	200 mg/lt.	400 mg/lt.	USEPA / APHA 24th -4500 SO4-E
8	Fluoride as F	0.07	1.0 mg/lt.	1.5 mg/lt.	APHA 24th Edition-4500F C/
9	Nitrate as No3	0.15	45 mg/lt.	45 mg/lt.	APHA 24th Edition -4500 NO3 D
10	pH @ 25°C	7.76	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B
11	Total Alkalinity	60	200 mg/lt.	600 mg/lt.	APHA 24th Edition -2320 B
12	Turbidity	0.08	1 NTU	5 NTU	APHA 24th Edition -2130 B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED BHIWANI Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by : Poince


RAJEEV KUMAR, CHEMIST
DISTRICT WATER TESTING LABORATORY BHIWANI
email:-chemist.bhiwani@phedharyana.gov.in

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY ,BHIWANI



Website :- <https://phedharyana.gov.in/>

Subject : **Bacteriological Examination Report of Water Samples**

Circle **Bhiwani Circle**

Division **Bhiwani PHED No. 2**

Sub Division **Bhiwani PHESD No. 2**

S.No.	Tested Parameter *	Result (MPN) **	Protocol Used	Potable / Not Potable
Memo No :- 1297, Date :- 15/10/2024				
1	Sample ID:-BHW/02373/10/2024 /Sender : VAISH MAHA VIDYALYA TRUST ,Location : , VAISH INTERNATIONAL SCHOOL, DEVSAR CHUNGI, Analysis Start/End Date: 14/10/2024 / 15/10/2024, GPS Coordinates: 76.130997 /28.785925			
	Total Coliform per 100 ml	00	IS 15185:2016/ APHA 9221C; 2017	Potable
Abstract Report of Bacteriological Examination Report of Water Sample				
Total Sample		Potable		Not Potable
1		1		0


* Requirement (Acceptable Limit) : Shall not be detectable in any 100 ml sample

** MPN (Most Probable Number) Per 100 ML.

Remarks :-

- * The Results Given above are related to the sample as received and tested in BHIWANI lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.

Sample analyzed by :


RAJEEV KUMAR, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, BHIWANI
email:-chemist.bhiwani@phedharyana.gov.in